

FACT SHEET FOR NPDES PERMIT NO. WA-003759-1
City of South Bend WWTP

TABLE OF CONTENTS

	<u>Page</u>
INTRODUCTION	1
GENERAL INFORMATION	2
BACKGROUND INFORMATION	2
DESCRIPTION OF THE FACILITY	2
Treatment Processes	2
Discharge Outfall and Dilution	2
DESCRIPTION OF THE RECEIVING WATER	3
PERMIT STATUS	3
WASTEWATER CHARACTERIZATION	4
PROPOSED PERMIT LIMITATIONS AND CONDITIONS	5
DESIGN CRITERIA	5
TECHNOLOGY-BASED EFFLUENT LIMITATIONS	6
SURFACE WATER QUALITY-BASED EFFLUENT LIMITATIONS	6
Consideration of Surface Water Quality-Based Criteria	6
MONITORING AND REPORTING	7
OTHER PERMIT CONDITIONS	7
PREVENTION OF FACILITY OVERLOADING	7
OPERATION AND MAINTENANCE (O&M)	8
RESIDUAL SOLIDS HANDLING	8
OUTFALL EVALUATION AND INFLUENT	8
GENERAL CONDITIONS	8
PERMIT ISSUANCE PROCEDURES	8
PERMIT MODIFICATIONS	8
RECOMMENDATION FOR PERMIT ISSUANCE	8
REVIEW BY THE PERMITTEE	8
APPENDIX A--PUBLIC INVOLVEMENT INFORMATION	9
APPENDIX B--GLOSSARY	10
APPENDIX C--RESPONSE TO COMMENTS	14
APPENDIX D--DILUTION MODEL RESULTS	15

INTRODUCTION

The Federal Clean Water Act (FCWA, 1972, and later modifications, 1977, 1981, and 1987) established water quality goals for the navigable (surface) waters of the United States. One of the mechanisms for achieving the goals of the Clean Water Act is the National Pollutant Discharge Elimination System (NPDES) permits which is administered by the Environmental Protection Agency (EPA). The EPA has delegated responsibility to administer the NPDES permit program to the state of Washington on the basis of Chapter 90.48 RCW which defines the Department of Ecology's (the Department) authority and obligations in administering the wastewater discharge permit program.

The regulations adopted by the state include procedures for issuing permits (Chapter 173-220 WAC), technical criteria for discharges from municipal wastewater treatment facilities (Chapter 173-221 WAC), and water quality criteria for surface and ground waters (Chapters 173-201A and 200 WAC). These regulations require that a permit be issued before discharge of wastewater to waters of the state is allowed. The regulations also establish the basis for effluent limitations and other requirements which are to be included in the permit.

This permit is issued to selected minor dischargers that, based on the available information, the Department believes have a relatively low environmental impact potential. The permit contains the technology-based effluent limitations as given in the Code of Federal Regulations (CFR) 40 CFR Part 133 (federal) and in Chapter 173-221 WAC (state). Due to a lack of adequate data indicating the discharger's potential for exceedance of the water quality standards, this permit does not include water quality-based numeric effluent limitations. However, a preliminary assessment of the discharge's potential for exceedance of the water quality standards for chlorine and ammonia is made. Based on this preliminary evaluation, the permit may include monitoring requirements and/or measures to control discharges of these toxic pollutants.

One of the requirements (WAC 173-220-060) for issuing a permit under the NPDES permit program is the preparation of a draft permit and an accompanying fact sheet. Public notice of the availability of the draft permit is required at least 30 days before the permit is issued (WAC 173-220-050). The fact sheet and draft permit are available for review (see Appendix A--Public Involvement of the fact sheet for more detail on the Public Notice procedures).

This fact sheet has been reviewed by the Permittee and errors in fact have been corrected. After the public comment period has closed, the Department will summarize the substantive comments and the response to each comment. The summary and response to comments (Appendix C) will become part of the file on the permit and parties submitting comments will receive a copy of the Department's response. The fact sheet will not be revised. Changes to the permit will be addressed in Appendix C--Response to Comments.

GENERAL INFORMATION

Applicant: City of South Bend
Facility Name and Address: City of South Bend Wastewater Treatment Plant
P.O. Drawer 9; South Bend, WA
Type of Treatment: Aerated/Facultative Lagoons
Discharge Location: Waterbody name: Willapa River Estuary
Latitude: 46° 40' 02" N. Longitude: 123° 48' 11" W.
Water Body ID Number: WA-24-2010

The outfall is located approximately at river mile 3.6 in the Willapa River estuary. The Willapa River estuary is near the mouth of the Willapa River which discharges to Willapa Bay. The location is near the city of South Bend in Pacific County.

BACKGROUND INFORMATION

DESCRIPTION OF THE FACILITY

TREATMENT PROCESSES

The treatment plant consists of a headworks with coarse manual screening, two partial mix aerated lagoons, two facultative lagoons, chlorine contact chamber, flow meter, dechlorination, and single port outfall to the Willapa River Estuary.

According to the permit application, there are no major industrial contributors to the sewer system.

The treatment plant is rated as a class I treatment plant. The operator in responsible charge is certified at the class II level. There are two operators for the facility. The operator in charge is also the city supervisor. He splits his time between the treatment plant and other duties in the city. The other operator also runs the water treatment plant and works at other duties as assigned.

The City of South Bend experiences severe high flows to the wastewater treatment plant during the winter wet months. The high flows cause permit violations at the treatment plant. The collection system also experiences overflows of raw sewage. The high flows seem to respond instantaneously to rainfall once the groundwater has risen. The high flows could be caused by inflow, although, direct infiltration cannot be ruled out. The City has formed a partnership with the City of Raymond. They have jointly applied to Washington State Department of Community Trade and Economic Development (WSC TED) for grant funding to correct their infiltration/inflow (I/I) problems. South Bend has reserved \$10,000 from their internal budget to apply toward I/I correction. Another \$52,000 for I/I correction is anticipated from Pacific County as part of the Eklund Park buy-in to connect them to sewer service with the City of South Bend.

*FACT SHEET FOR NPDES PERMIT NO. WA-003759-1
City of South Bend WWTP*

DISCHARGE OUTFALL AND DILUTION

Secondary treated and disinfected effluent is discharged from the facility via a continuously submerged single port diffuser into the Willapa River Estuary.

The dilution factors for acute and chronic conditions during the critical low flow period were estimated using the Plumes UM Dilution Model, Third Addition, April 1994. River profiles from the Raymond dilution study of October 1995 (Cosmopolitan Engineering Group) were used as input for the modeling work. The most conservative tidal cycle salinity profiles which produced the lowest acute and chronic dilution for Raymond served as input to the model for South Bend. The Raymond far-field ambient concentration of .35 percent (corrected for reflux effects) was adjusted mathematically to compute the ambient concentration for the South Bend modeling.

The critical low flow dilution factors estimated for South Bend's discharge which include reflux effect are as follows:

ACUTE: 47

CHRONIC: 167

DESCRIPTION OF THE RECEIVING WATER

The facility discharges to the Willapa River Estuary which is designated as a Class A receiving water in the vicinity of the outfall. Other nearby point source outfalls include the City of Raymond's WWTP outfall upstream of South Bend. Significant nearby non-point sources of pollutants include cattle grazing and failing septic systems. Characteristic uses include the following:

water supply (domestic, industrial, agricultural); stock watering; fish migration; fish and shellfish rearing, spawning and harvesting; wildlife habitat; primary contact recreation; sport fishing; boating and aesthetic enjoyment; commerce and navigation.

Water quality of this class shall meet or exceed the requirements for all or substantially all uses.

PERMIT STATUS

The previous permit for this facility was issued on September 25, 1986. The previous permit placed effluent limitations on 5-day Biochemical Oxygen Demand (BOD₅), Total Suspended Solids (TSS), pH, Fecal Coliform Bacteria, and Chlorine Residual.

CURRENT EFFLUENT LIMITATIONS

<u>Parameter</u>	<u>Monthly Average</u>	<u>Weekly Average</u>
Biochemical Oxygen Demand	30 mg/l, 91 lbs/day	45 mg/l, 137 lbs/day
Suspended Solids	75 mg/l, 228 lbs/day	112.5 mg/l, 341 lbs/day
Fecal Coliform Bacteria	200/100 ml	400/100 ml
Chlorine Residual		0.002 mg/l *
pH	Shall not be outside the range of 6.0 to 9.0	

* Total available (residual) chlorine shall be undetectable as measured by HACH Colorimeter.

*FACT SHEET FOR NPDES PERMIT NO. WA-003759-1
City of South Bend WWTP*

The monthly average effluent concentration limitation for BOD5 shall not exceed 30 mg/L or 15 percent of the respective influent concentrations, whichever is more stringent.

Since the dilution factors for both the critical and acute conditions are both above 20, there is very low environmental risk associated with ammonia. Since there is no major industries contributing flows to the wastewater system, the environmental risk from industrial toxins is low. Because of the low environmental risk, no effluent limits will be established for ammonia or other toxins except chlorine. Since a limit for chlorine had already been established in the previous permit and dechlorination equipment is already in place, the existing chlorine limit will be continued in this permit.

The following are proposed limits for the South Bend Wastewater Facility:

PROPOSED EFFLUENT LIMITATIONS		
<u>Parameter</u>	<u>Monthly Average</u>	<u>Weekly Average</u>
Biochemical Oxygen Demand	30 mg/l***	45 mg/l, 137 lbs/day
Suspended Solids	75 mg/l***	112.5 mg/l, 341 lbs/day
Fecal Coliform Bacteria	200/100 ml	400/100 ml
Chlorine Residual		0.002 mg/l*
pH	Shall not be outside the range of 6.0 to 10.5**	

*Total available (residual) chlorine shall be undetectable as measured by HACH Colorimeter.

The month average effluent concentration limitation for BOD5 shall not exceed 30 mg/l or 35 percent** of the respective influent concentrations, whichever is more stringent.

**Alternative limits were applied to the BOD5 percent removal and pH for the following reasons. The percent removal for BOD5 was lowered to 65 from 85 percent as allowed in WAC 173-221-050. The 5th percentile for the BOD5 percent removal was 70 percent. Since the plant is a waste stabilization pond and cannot consistently meet the 85 percent removal requirement for BOD5, the alternative limit of 65 percent removal was applied. The effluent pH ranges up into the 10's because of algae stripping the acidic carbon dioxide from the lagoon water. The high pH is not due to industrial sources or added chemicals. It is a natural benign process occurring in the lagoon. Therefore, the maximum allowable pH was increased from 9 to 10.5 as allowed in WAC 173-221-040.

***The plant can meet the 30 mg/l BOD5 limit based on the 95th percentile of effluent DMR data. The plant can meet 71 mg/l Total Suspended Solids limit based on the 95th percentile of effluent data. The limit of 75 mg/l TSS was retained since it is close to what the plant can achieve and is their current permit limit for that parameter. It is also allowed in WAC 173-221-050.

An application for permit renewal was submitted to the Department on June 24, 1996, and accepted by the Department on July 31, 1996.

WASTEWATER CHARACTERIZATION

The concentration of pollutants in the discharge was reported in the NPDES application and in discharge monitoring reports. The effluent is characterized as follows:

Table 1: Wastewater Characterization

<u>Parameter</u>	<u>Annual Average</u>	<u>Range</u>
Flow	0.43 MGD	0.19 - 0.77 MGD
Biochemical Oxygen Demand (5 day)	21 mg/l	14 - 30 mg/l
Suspended Solids	37 mg/l	21 - 57 mg/l
Chlorine Residual	0.034 mg/l	0.009 - 0.11 mg/l
pH		6.2 - 10.5
Temperature	9.3 Deg. Celsius	-5 - 24 Deg. Celsius
Fecal Coliform	Highest monthly average 395 colonies/100 ml	

PROPOSED PERMIT LIMITATIONS AND CONDITIONS

Federal and state regulations require that effluent limitations set forth in a NPDES permit must be either technology- or water quality-based. Technology-based limitations for municipal discharges are set by regulation (40 CFR 133, and Chapters 173-220 and 173-221 WAC). Water quality-based limitations are based upon compliance with the Surface Water Quality Standards (Chapter 173-201A WAC), Ground Water Standards (Chapter 173-200 WAC), or Sediment Quality Standards (Chapter 173-204 WAC). The most stringent of these types of limits must be chosen for each of the parameters of concern. Each of these types of limits is described in more detail below.

DESIGN CRITERIA

In accordance with Washington Administrative Code (WAC) 173-220-130(1)(a), effluent limitations shall not be less stringent than those based upon the design criteria for the facility which are contained in approved engineering plans, reports, or approved revisions. Also, in accordance with WAC 173-220-150 (1)(g), flows or waste loadings shall not exceed approved design criteria.

The design criteria for this treatment facility are taken from the 1984 plans and specifications prepared by Kramer, Chin & Mayo, Inc. and are as follows:

Table 2: Design Standards for the South Bend WWTP.

Parameter	Design Quantity
Monthly average flow (max month)	0.69 MGD
Monthly average dry weather flow	0.375 MGD
Monthly average wet weather flow	0.69 MGD
Instantaneous peak flow	1.56 MGD
BOD influent loading	608 lb./day
TSS influent loading	608 lb./day
Design population equivalent	3040

TECHNOLOGY-BASED EFFLUENT LIMITATIONS

Municipal wastewater treatment plants are a category of discharger for which technology-based effluent limits have been promulgated by federal and state regulations. These effluent limitations are given in the Code of Federal Regulations (CFR) 40 CFR Part 133 (federal) and in Chapter 173-221 WAC (state). These regulations are performance standards that constitute all known available and reasonable methods of prevention, control, and treatment for municipal wastewater.

SURFACE WATER QUALITY-BASED EFFLUENT LIMITATIONS

In order to protect existing water quality and preserve the designated beneficial uses of Washington's surface waters, WAC 173-201A-060 states that waste discharge permits shall be conditioned such that the discharge will meet established Surface Water Quality Standards. The Washington State Surface Water Quality Standards (Chapter 173-201A WAC) is a state regulation designed to protect the beneficial uses of the surface waters of the state.

Due to a lack of adequate data indicating the discharger's potential for exceedance of the water quality standards, this permit does not include water quality-based numeric effluent limitations. Also, in the absence of data indicating otherwise, the discharge is believed to have a relatively low environmental impact potential and, therefore, the permit does not have extensive effluent and receiving water data gathering and monitoring requirements. However, a preliminary assessment was conducted of the discharge's potential for exceedance of the water quality standards for chlorine and ammonia are made. Based on this preliminary evaluation, described in the following section, the permit will not include monitoring and measures to control discharges of these toxic pollutants.

CONSIDERATION OF SURFACE WATER QUALITY-BASED CRITERIA

Critical Conditions

Determination of the reasonable potential for exceedance of the surface water standards quality standards are made for the waterbody's critical condition which represents the receiving water and waste discharge condition with the highest potential for adverse impact on the aquatic biota, human health, and existing or characteristic water body uses.

Mixing Zones

The Water Quality Standards allow the Department to authorize mixing zones around a point of discharge in establishing surface water quality-based effluent limits. Both "acute" and "chronic" mixing zones may be authorized for pollutants that can have a toxic effect on the aquatic environment near the point of discharge. The concentration of pollutants at the boundary of these mixing zones may not exceed the numerical criteria for that type of zone. Mixing zones can only be authorized for discharges that are receiving all known, available, and reasonable methods of prevention and control (AKART) and in accordance with other mixing zone requirements of WAC 173-201A-100.

Preliminary Dilution Factor Estimation

When pollutant concentrations in the proposed discharge exceed water quality criteria with technology-based controls which the Department has determined to be AKART, mixing zones may be authorized in accordance with Chapter 173-201A WAC.

Mathematical models and/or dye studies may be used to determine the dilution factors of effluent to receiving water that occur within the allowable mixing zones at the critical condition. The dilution factors determined will then be compared with those based on the allowable river flow percents (WAC 173-201).

Chlorine Considerations

Since the South Bend plant has a reliable dechlorination system in place, no discussion of chlorine is necessary.

MONITORING AND REPORTING

Effluent monitoring, recording, and reporting are required (WAC 173-220-210 and 40 CFR 122.41) to verify that the treatment process is functioning correctly and the effluent limitations are being achieved.

The monitoring and testing schedule is detailed in the proposed permit under Condition S.2. Specified monitoring frequencies take into account the quantity and variability of discharge, the treatment method, past compliance, significance of pollutants, and cost of monitoring. The required monitoring frequency is consistent with agency guidance given in the current version of the Department Permit Writer's Manual. This frequency of monitoring is considered to be the minimum frequency to document compliance for a typical facility of this size.

OTHER PERMIT CONDITIONS

PREVENTION OF FACILITY OVERLOADING

Overloading of the treatment plant is a violation of the terms and conditions of the permit. To prevent this from occurring, RCW 90.48.110 and WAC 173-220-150 require the Permittee to take the actions detailed in proposed permit requirement S.4. to plan expansions or modifications before existing capacity is reached and to report and correct conditions that could result in new or increased discharges of pollutants. Condition S.4. restricts the amount of flow.

*FACT SHEET FOR NPDES PERMIT NO. WA-003759-1
City of South Bend WWTP*

OPERATION AND MAINTENANCE (O&M)

The proposed permit contains condition S.5. as authorized under RCW 90.48.110, WAC 173-220-150, Chapter 173-230 WAC, and WAC 173-240-080. It is included to ensure proper operation and regular maintenance of equipment and to ensure that adequate safeguards are taken so that constructed facilities are used to their optimum potential in terms of pollutant capture and treatment.

RESIDUAL SOLIDS HANDLING

To prevent water quality problems the Permittee is required in permit condition S7. to store and handle all residual solids (grit, screenings, scum, sludge, and other solid waste) in accordance with the requirements of RCW 90.48.080 and state Water Quality Standards.

The final use and disposal of sewage sludge from this facility is regulated by U.S. EPA under 40 CFR 503. The disposal of other solid waste is regulated by the jurisdictional health department.

OUTFALL EVALUATION AND INFLUENT

Proposed permit condition S.10. requires the Permittee to conduct an outfall inspection and submit a report detailing the findings of that inspection. The purpose of the inspection is to determine the condition of the discharge pipe and diffuser and the influent line.

GENERAL CONDITIONS

General Conditions are based directly on state and federal law and regulations and have been standardized for all individual NPDES permits issued by the Department.

PERMIT ISSUANCE PROCEDURES

PERMIT MODIFICATIONS

The Department may modify this permit to impose numerical limitations, if necessary to meet Water Quality Standards, Sediment Quality Standards, or Ground Water Standards, based on new information obtained from sources such as inspections, effluent monitoring, outfall studies, and effluent mixing studies.

The Department may also modify this permit as a result of new or amended state or federal regulations.

RECOMMENDATION FOR PERMIT ISSUANCE

This proposed permit meets all statutory requirements for authorizing a wastewater discharge, including those limitations and conditions believed necessary to protect human health, aquatic life, and the beneficial uses of waters of the state of Washington. The Department proposes that this permit be issued for five years.

REVIEW BY THE PERMITTEE

A proposed permit was reviewed by the Permittee for verification of facts. Only factual items were corrected in the draft permit and fact sheet.

APPENDIX A--PUBLIC INVOLVEMENT INFORMATION

The Department has tentatively determined to reissue a permit to the applicant listed on page 1 of this fact sheet. The permit contains conditions and effluent limitations which are described in the rest of this fact sheet.

Public notice of application was published on September 5, 1996, in the Wahkiakum County Eagle to inform the public that an application had been submitted and to invite comment on the reissuance of this permit.

The Department will publish a Public Notice of Draft (PNOD) in the Wahkiakum County Eagle to inform the public that a draft permit and fact sheet are available for review. Interested persons are invited to submit written comments regarding the draft permit. The draft permit, fact sheet, and related documents are available for inspection and copying between the hours of 8:00 a.m. and 5:00 p.m. weekdays, by appointment, at the regional office listed below. Written comments should be mailed to:

Water Quality Permit Coordinator
Department of Ecology
Southwest Regional Office
P.O. Box 47775
Olympia, WA 98504-7775.

Any interested party may comment on the draft permit or request a public hearing on this draft permit within the thirty (30) day comment period to the address above. The request for a hearing shall indicate the interest of the party and the reasons why the hearing is warranted. The Department will hold a hearing if it determines there is a significant public interest in the draft permit (WAC 173-220-090). Public notice regarding any hearing will be circulated at least thirty (30) days in advance of the hearing. People expressing an interest in this permit will be mailed an individual notice of hearing (WAC 173-220-100).

The Department will consider all comments received within thirty (30) days from the date of public notice of draft indicated above, in formulating a final determination to issue, revise, or deny the permit. The Department's response to all significant comments is available upon request and will be mailed directly to people expressing an interest in this permit.

Further information may be obtained from the Department by telephone, (360)407-6279, or by writing to the address listed above.

APPENDIX B--GLOSSARY

Acute Toxicity--The lethal effect of a compound on an organism that occurs in a short period of time, usually 48 to 96 hours.

Ambient Water Quality--The existing environmental condition of the water in a receiving water body.

Ammonia--Ammonia is produced by the breakdown of nitrogenous materials in wastewater. Ammonia is toxic to aquatic organisms, exerts an oxygen demand, and contributes to eutrophication. It also increases the amount of chlorine needed to disinfect wastewater.

Best Management Practices (BMPs)--Schedules of activities, prohibitions of practices, maintenance procedures, and other physical, structural and/or managerial practices to prevent or reduce the pollution of waters of the state. BMPs include treatment systems, operating procedures, and practices to control: plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage. BMPs may be further categorized as operational, source control, erosion and sediment control, and treatment BMPs.

BOD₅--Determining the Biochemical Oxygen Demand of an effluent is an indirect way of measuring the quantity of organic material present in an effluent that is utilized by bacteria. The BOD₅ is used in modeling to measure the reduction of dissolved oxygen in a receiving water after effluent is discharged. Stress caused by reduced dissolved oxygen levels makes organisms less competitive and less able to sustain their species in the aquatic environment. Although BOD is not a specific compound, it is defined as a conventional pollutant under the federal Clean Water Act.

Bypass--The intentional diversion of waste streams from any portion of a treatment facility.

Chlorine--Chlorine is used to disinfect wastewaters of pathogens harmful to human health. It is also extremely toxic to aquatic life.

Chronic Toxicity--The effect of a compound on an organism over a relatively long time, often 1/10 of an organism's lifespan or more. Chronic toxicity can measure survival, reproduction or growth rates, or other parameters to measure the toxic effects of a compound or combination of compounds.

Class 1 Inspection--A walk-through inspection of a facility that includes a visual inspection and some examination of facility records. It may also include a review of the facility's record of environmental compliance.

Class 2 Inspection--A walk-through inspection of a facility that includes the elements of a Class 1 Inspection plus sampling and testing of wastewaters. It may also include a review of the facility's record of environmental compliance.

Clean Water Act (CWA)--The Federal Water Pollution Control Act enacted by Public Law 92-500, as amended by Public Laws 95-217, 95-576, 96-483, 97-117; USC 1251 et seq.

Combined Sewer Overflow (CSO)--The event during which excess combined sewage flow caused by inflow is discharged from a combined sewer, rather than conveyed to the sewage treatment plant because either the capacity of the treatment plant or the combined sewer is exceeded.

Composite Sample--A mixture of grab samples collected at the same sampling point at different times, formed either by continuous sampling or by mixing discrete samples. May be "time-composite"(collected at constant time intervals) or "flow-proportional" (collected either as a constant sample volume at time intervals proportional to stream flow, or collected by increasing the volume of each aliquot as the flow increased while maintaining a constant time interval between the aliquots).

FACT SHEET FOR NPDES PERMIT NO. WA-003759-1
City of South Bend WWTP

Construction Activity--Clearing, grading, excavation and any other activity which disturbs the surface of the land. Such activities may include road building, construction of residential houses, office buildings, or industrial buildings, and demolition activity.

Critical Condition--The time during which the combination of receiving water and waste discharge conditions have the highest potential for causing toxicity in the receiving water environment. This situation usually occurs when the flow within a water body is low, thus, its ability to dilute effluent is reduced.

Daily Maximum Discharge Limitation--The greatest allowable value for any calendar day.

Dilution Factor--A measure of the amount of mixing of effluent and receiving water that occurs at the boundary of the mixing zone. Expressed as the inverse of the effluent fraction.

Engineering Report--A document which thoroughly examines the engineering and administrative aspects of a particular domestic or industrial wastewater facility. The report shall contain the appropriate information required in WAC 173-240-060 or 173-240-130.

Fecal Coliform Bacteria--Fecal coliform bacteria are used as indicators of pathogenic bacteria in the effluent that are harmful to humans. Pathogenic bacteria in wastewater discharges are controlled by disinfecting the wastewater. The presence of high numbers of fecal coliform bacteria in a water body can indicate the recent release of untreated wastewater and/or the presence of animal feces.

Grab Sample--A single sample or measurement taken at a specific time or over as short period of time as is feasible.

Industrial Wastewater--Water or liquid-carried waste from industrial or commercial processes, as distinct from domestic wastewater. These wastes may result from any process or activity of industry, manufacture, trade or business, from the development of any natural resource, or from animal operations such as feed lots, poultry houses, or dairies. The term includes contaminated storm water and, also, leachate from solid waste facilities.

Infiltration and Inflow (I/I)--"Infiltration" means the addition of ground water into a sewer through joints, the sewer pipe material, cracks, and other defects. "Inflow" means the addition of rainfall-caused surface water drainage from roof drains, yard drains, basement drains, street catch basins, etc., into a sewer.

Mixing Zone--An area that surrounds an effluent discharge within which water quality criteria may be exceeded. The area of the authorized mixing zone is specified in a facility's permit and follows procedures outlined in state regulations (Chapter 173-201A WAC).

Monthly Average Discharge Limitation--The average of the measured values obtained over a calendar month's time.

National Pollutant Discharge Elimination System (NPDES)--The NPDES (Section 402 of the Clean Water Act) is the federal wastewater permitting system for discharges to navigable waters of the United States. Many states, including the state of Washington, have been delegated the authority to issue these permits. NPDES permits issued by Washington state permit writers are joint NPDES/State permits issued under both state and federal laws.

pH--The pH of a liquid measures its acidity or alkalinity. A pH of 7 is defined as neutral, and large variations above or below this value are considered harmful to most aquatic life.

State Waters--Lakes, rivers, ponds, streams, inland waters, underground waters, salt waters, and all other surface waters and watercourses within the jurisdiction of the state of Washington.

Stormwater--That portion of precipitation that does not naturally percolate into the ground or evaporate, but flows via overland flow, interflow, pipes, and other features of a storm water drainage system into a defined surface water body, or a constructed infiltration facility.

Technology-based Effluent Limit--A permit limit that is based on the ability of a treatment method to reduce the pollutant.

Total Suspended Solids (TSS)--Total suspended solids is the particulate material in an effluent. Large quantities of TSS discharged to a receiving water may result in solids accumulation. Apart from any toxic effects attributable to substances leached out by water, suspended solids may kill fish, shellfish, and other aquatic organisms by causing abrasive injuries and by clogging the gills and respiratory passages of various aquatic fauna. Indirectly, suspended solids can screen out light and can promote and maintain the development of noxious conditions through oxygen depletion.

Upset--An exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, lack of preventative maintenance, or careless or improper operation.

Water Quality-based Effluent Limit--A limit on the concentration of an effluent parameter that is intended to prevent the concentration of that parameter from exceeding its water quality criterion after it is discharged into a receiving water.

*FACT SHEET FOR NPDES PERMIT NO. WA-003759-1
City of South Bend WWTP*

APPENDIX C--RESPONSE TO COMMENTS